KNOWLEDGE: K1.07 [3.5/3.5] KNOWLEDGE: K1.08 [2.7/2.8] QID: B186 (P44)

Control rod withdrawal has increased $K_{\rm eff}$ from 0.998 to 1.002. The reactor currently is...

- A. subcritical.
- B. supercritical.
- C. prompt critical.
- D. exactly critical.

ANSWER: B.

TOPIC: 292002

KNOWLEDGE: K1.07 [3.5/3.5] QID: B247 (P445)

Which one of the following conditions describes a nuclear reactor that is exactly critical?

A.
$$K_{eff} = 0$$
; $\Delta K/K = 0$

B.
$$K_{eff} = 0$$
; $\Delta K/K = 1$

C.
$$K_{eff} = 1$$
; $\Delta K/K = 0$

D.
$$K_{eff} = 1$$
; $\Delta K/K = 1$

KNOWLEDGE: K1.08 [2.7/2.8]

QID: B46

Which one of the following does \underline{not} affect $K_{\mbox{\tiny eff}}$?

- A. core dimensions.
- B. core burnup.
- C. moderator-to-fuel ratio.
- D. installed neutron sources.

ANSWER: D.

TOPIC: 292002

KNOWLEDGE: K1.08 [2.7/2.8]

QID: B348

Which one of the following, if decreased, will \underline{not} affect K_{eff} ?

- A. Fuel enrichment
- B. Control rod worth
- C. Neutron contribution from neutron sources
- D. Shutdown margin when the reactor is subcritical

TOPIC: KNOWLEDGE: QID:			
the end of one ger		on factor (K_{eff}) describes the ratio of to the number of fission neutrons at t	
A. beginning; nex	xt		
B. beginning; pre	evious		
C. end; next			
D. end; previous			
ANSWER: D.			
TOPIC: KNOWLEDGE: QID:			
		on factor (K_{eff}) can be determined by e number of neutrons in the	
A. first			
B. second			
C. third			
D. fourth			
ANSWER: B.			

KNOWLEDGE: K1.08 [2.7/2.8] QID: B2647 (P2647)

A thermal neutron is about to interact with a U-238 nucleus in an operating reactor core. Which one of the following describes the most likely interaction and the effect on core K_{eff} ?

- A. The neutron will be scattered, thereby leaving K_{eff} unchanged.
- B. The neutron will be absorbed and U-238 will undergo fission, thereby decreasing $K_{\rm eff}$.
- C. The neutron will be absorbed and U-238 will undergo fission, thereby increasing K_{eff} .
- D. The neutron will be absorbed and U-238 will undergo radioactive decay to Pu-239, thereby increasing $K_{\rm eff}$.

ANSWER: A.

TOPIC: 292002

KNOWLEDGE: K1.08 [2.7/2.8] QID: B3147 (P3046)

A reactor plant is currently operating at equilibrium 80% power near the end of its fuel cycle. During the next 3 days of equilibrium power operation <u>no</u> operator action is taken.

How will core K_{eff} be affected during the 3-day period?

- A. Core K_{eff} will gradually increase during the entire period.
- B. Core K_{eff} will gradually decrease during the entire period.
- C. Core K_{eff} will tend to increase, but inherent reactivity feedback will maintain K_{eff} at 1.0.
- D. Core K_{eff} will tend to decrease, but inherent reactivity feedback will maintain K_{eff} at 1.0.

ANSWER: D.

KNOWLEDGE: K1.09 [2.4/2.6] QID: B1147 (N/A)

Which one of the following combinations of core conditions at 30% power indicates the <u>largest</u> amount of excess reactivity exists in the core?

CONTROL ROD <u>POSITION</u>	REACTOR RECIR- CULATION FLOW			
A. 25% rod density	25%			
B. 50% rod density	50%			
C. 25% rod density	50%			
D. 50% rod density	25%			
ANSWER: D.				

TOPIC: 292002

KNOWLEDGE: K1.09 [2.4/2.6] QID: B1247 (N/A)

Which one of the following combinations of core conditions at 35% power indicates the <u>least</u> amount of excess reactivity exists in the core?

CONTROL	REACTOR RECIR-				
ROD POSITION	CULATION FLOW				
A. 50% inserted	50%				
B. 50% inserted	25%				
C. 25% inserted	50%				
D. 25% inserted	25%				
ANSWER: C.					

KNOWLEDGE: K1.09 [2.4/2.6] QID: B1848 (P646)

Which one of the following defines K-excess?

- A. $K_{eff} 1$
- B. $K_{eff} + 1$
- C. $(K_{eff}-1)/K_{eff}$
- D. $(1-K_{eff})/K_{eff}$

ANSWER: A.

TOPIC: 292002

KNOWLEDGE: K1.09 [2.4/2.6] QID: B2048 (P1246)

Which one of the following is a reason for installing excess reactivity (K_{excess}) in the core?

- A. To compensate for burnout of Xe-135 and Sm-149 during power changes.
- B. To ensure the fuel temperature coefficient remains negative throughout core life.
- C. To compensate for the negative reactivity added by the power coefficient during a power increase.
- D. To compensate for the conversion of U-238 to Pu-239 over core life.

KNOWLEDGE: K1.09 [2.4/2.6] QID: B2747 (P2847)

A reactor is operating at full power at the beginning of a fuel cycle. A neutron has just been absorbed by a U-238 nucleus at a resonance energy of 6.7 electron volts.

Which one of the following describes the most likely reaction for the newly formed U-239 nucleus and the effect of this reaction on K_{excess} ?

- A. Decays over several days to Pu-239, which increases K_{excess} .
- B. Decays over several days to Pu-240, which increases K_{excess} .
- C. Immediately undergoes fast fission, which decreases K_{excess}.
- D. Immediately undergoes thermal fission, which decreases K_{excess} .

ANSWER: A.

ANSWER: B.

TOPIC: 292002

KNOWLEDGE: K1.09 [2.4/2.6] QID: B2947 (N/A)

The following are combinations of critical conditions that may exist for the same reactor operating at 50% power at different times in core life. Which one of the following combinations indicates the <u>largest</u> amount of excess reactivity present in the reactor fuel?

CONTROL ROD POSITION	REACTOR RECIR- CULATION FLOW
A. 25% rod density	75%
B. 50% rod density	50%
C. 25% rod density	50%
D. 50% rod density	75%

KNOWLEDGE: K1.09 [2.4/2.6]

QID: B3447

The following are combinations of critical conditions that existed for the same reactor operating at 50% power at different times in core life. Which one of the following combinations indicates the <u>smallest</u> amount of excess reactivity present in the reactor fuel?

CONTROL ROD POSITION	REACTOR RECIR- CULATION FLOW
A. 25% rod density	75%
B. 50% rod density	50%
C. 25% rod density	50%
D. 50% rod density	75%
ANSWER: A.	

TOPIC:

KNOWLEDGE: K1.09 [2.4/2.6] QID: B3547 (P3547)

292002

Which one of the following is a benefit of installing excess reactivity (K_{excess}) in a reactor core?

- A. Ensures that sufficient control rod negative reactivity is available to shut down the reactor.
- B. Ensures that the reactor can be made critical during a peak xenon condition after a reactor scram.
- C. Ensures that positive reactivity additions result in controllable reactor power responses.
- D. Ensures that the U-235 fuel enrichment is the same at the beginning and the end of a fuel cycle.

KNOWLEDGE: K1.10 [3.2/3.5] B248 QID: (P245)

When determining shutdown margin for an operating reactor, how many control rod assemblies are assumed to remain fully withdrawn?

- A. A single control rod of the highest reactivity worth
- B. A symmetrical pair of control rods of the highest reactivity worth
- C. A single control rod of average reactivity worth
- D. A symmetrical pair of control rods of average reactivity worth

ANSWER: A.

TOPIC: 292002

KNOWLEDGE: K1.10 [3.2/3.5] QID: B1348 (N/A)

Shutdown margin for an operating reactor is the amount of reactivity by which a xenon-free reactor at 68°F would be subcritical if all control rods were...

- A. withdrawn, assuming an average worth rod remains fully inserted.
- B. inserted, assuming an average worth rod remains fully withdrawn.
- C. withdrawn, assuming the highest worth rod remains fully inserted.
- D. inserted, assuming the highest worth rod remains fully withdrawn.

ANSWER: D.

TOPIC: 292002

KNOWLEDGE: K1.11 [3.2/3.3]

QID: B47

The fractional change in neutron population from one generation to the next is called...

- A. beta.
- B. K_{eff}.
- C. lambda.
- D. reactivity.

ANSWER: D.

TOPIC: 292002

KNOWLEDGE: K1.12 [2.4/2.5] QID: B648 (P1946)

In a subcritical reactor, K_{eff} was increased from 0.85 to 0.95 by rod withdrawal. Which one of the following is closest to the amount of reactivity that was added to the core?

- A. $0.099 \Delta K/K$
- B. $0.124 \Delta K/K$
- C. $0.176 \Delta K/K$
- D. 0.229 ΔK/K

ANSWER: B.

TOPIC: 292002

KNOWLEDGE: K1.12 [2.4/2.5] QID: B748 (P3347)

With K_{eff} equal to 0.983, how much reactivity must be added to make the reactor <u>exactly</u> critical? (Round answer to nearest 0.01% $\Delta K/K$.)

- A. $1.70\% \Delta K/K$
- B. 1.73% ΔK/K
- C. $3.40\% \Delta K/K$
- D. 3.43% ΔK/K

KNOWLEDGE: K1.12 [2.4/2.5] QID: B1548 (P446)

With core K_{eff} equal to 0.987, how much reactivity must be added to make a reactor <u>exactly</u> critical? (Answer options are rounded to the nearest 0.01% $\Delta K/K$.)

- A. $1.01\% \Delta K/K$
- B. $1.03\% \Delta K/K$
- C. $1.30\% \Delta K/K$
- D. 1.32% ΔK/K

ANSWER: D.

TOPIC: 292002

KNOWLEDGE: K1.12 [2.4/2.5] QID: B1947 (P2447)

With $K_{eff} = 0.985$, how much positive reactivity is required to make the reactor exactly critical?

- Α. 1.487% ΔΚ/Κ
- B. 1.500% ΔK/K
- C. 1.523% ΔK/K
- D. 1.545% ΔK/K

TOPIC: 292002 KNOWLEDGE: K1.12 [2.4/2.5] B2848 (P2146) QID: With $K_{eff} = 0.982$, how much positive reactivity is required to make the reactor critical? Α. 1.720% ΔΚ/Κ B. 1.767% ΔK/K C. 1.800% ΔK/K D. 1.833% ΔK/K ANSWER: D. TOPIC: 292002 KNOWLEDGE: K1.14 [2.6/2.9] B548 QID: The shutdown margin (SDM), upon full insertion of all control rods following a reactor scram from full power, is the SDM immediately prior to the scram. A. equal to B. less than C. greater than D. independent of ANSWER: A.

TOPIC: 292002

KNOWLEDGE: K1.14 [2.6/2.9]

QID: B948

Which one of the following core changes will decrease shutdown margin?

- A. Fuel depletion during reactor operation
- B. Buildup of Sm-149 after a reactor scram
- C. Increasing moderator temperature 10°F while shutdown
- D. Depletion of gadolinium during reactor operation

ANSWER: D.

TOPIC: 292002

KNOWLEDGE: K1.14 [2.6/2.9]

QID: B1048

One hour ago, a reactor scrammed from 100% steady state power due to an instrument malfunction. All systems operated normally. Given the following absolute values of reactivities added since the scram, assign a (+) or (-) as appropriate and choose the current value of core reactivity.

Xenon = () 1.0% Δ K/K Fuel temperature = () 2.0% Δ K/K Control rods = () 14.0% Δ K/K Voids = () 3.0% Δ K/K

A. $-8.0\% \Delta K/K$

B. $-10.0\% \Delta K/K$

C. $-14.0\% \Delta K/K$

D. $-20.0\% \Delta K/K$

TOPIC: 292002

KNOWLEDGE: K1.14 [2.6/2.9]

QID: B1248

Which one of the following will increase the reactivity margin to criticality in a subcritical reactor at $250^{\circ}F$?

- A. Decay of Samarium-149
- B. Increased core recirculation flow rate
- C. Reactor coolant heatup
- D. Control rod withdrawal

TOPIC: 292002

KNOWLEDGE: K1.14 [2.6/2.9]

QID: B1648

A reactor scrammed from 100% steady state power due to an instrument malfunction 16 hours ago. All systems operated normally.

Given the following absolute values of reactivities added since the scram, assign a (+) or (-) as appropriate and choose the current value of core reactivity.

Xenon = () 1.5% Δ K/K Fuel temperature = () 2.5% Δ K/K Control rods = () 14.0% Δ K/K Voids = () 3.5% Δ K/K

- A. $-6.5\% \Delta K/K$
- B. -9.5% ΔK/K
- C. -11.5% ΔK/K
- D. $-13.5\% \Delta K/K$

TOPIC: 292002

KNOWLEDGE: K1.14 [2.6/2.9]

QID: B1748

Twelve (12) hours ago, a reactor scrammed from 100% steady state power due to an instrument malfunction. All systems operated normally. Given the following absolute values of reactivities added since the scram, assign a (+) or (-) as appropriate and choose the current value of core reactivity.

Xenon = () $2.0\% \Delta K/K$ Fuel temperature = () $2.5\% \Delta K/K$ Control rods = () $14.0\% \Delta K/K$ Voids = () $4.5\% \Delta K/K$

- A. $-5.0\% \Delta K/K$
- B. $-9.0\% \Delta K/K$
- C. $-14.0\% \Delta K/K$
- D. -23.0% ΔK/K

TOPIC: 292002

KNOWLEDGE: K1.14 [2.6/2.9]

QID: B2148

A reactor scram from 100% steady-state power occurred 36 hours ago due to an instrument malfunction. All systems operated normally.

Given the following absolute values of reactivities added since the scram, assign a (+) or (-) as appropriate and choose the current value of core reactivity.

Xenon = () 1.0% Δ K/K Fuel temperature = () 2.0% Δ K/K Control rods = () 14.0% Δ K/K Voids = () 3.0% Δ K/K

- A. $-8.0\% \Delta K/K$
- B. $-10.0\% \Delta K/K$
- C. $-14.0\% \Delta K/K$
- D. $-20.0\% \Delta K/K$

ANSWER: A.

TOPIC: 292002

KNOWLEDGE: K1.14 [2.6/2.9]

QID: B2248

Sixteen hours ago, a reactor scrammed from 100% steady state power due to an instrument malfunction. All systems operated normally. Given the following absolute values of reactivities added since the scram, assign a (+) or (-) as appropriate and choose the current value of core reactivity.

Xenon = () $2.0\% \Delta K/K$ Fuel temperature = () $3.0\% \Delta K/K$ Control rods = () $12.0\% \Delta K/K$ Voids = () $4.0\% \Delta K/K$

- A. $-5.0\% \Delta K/K$
- B. $-7.0\% \Delta K/K$
- C. $-9.0\% \Delta K/K$
- D. $-11.0\% \Delta K/K$

KNOWLEDGE: K1.14 [2.6/2.9] QID: B2348 (P2347)

Which one of the following core changes will <u>decrease</u> shutdown margin? Assume no operator actions.

- A. Depletion of fuel during reactor operation
- B. Depletion of burnable poisons during reactor operation
- C. Buildup of Sm-149 following a reactor power transient
- D. Buildup of Xe-135 following a reactor power transient

TOPIC: 292002

KNOWLEDGE: K1.14 [2.6/2.9]

QID: B2448

A reactor scrammed from 100% steady state power due to an instrument malfunction 30 hours ago. All systems operated normally.

Given the following absolute values of reactivities added since the scram, assign a (+) or (-) as appropriate and choose the current value of core reactivity.

Xenon = () 1.5% Δ K/K Fuel temperature = () 2.5% Δ K/K Control rods = () 14.0% Δ K/K Voids = () 3.5% Δ K/K

- A. $-6.5\% \Delta K/K$
- B. -9.5% ΔK/K
- C. -11.5% ΔK/K
- D. $-13.5\% \Delta K/K$

ANSWER: A.

KNOWLEDGE: K1.14 [2.6/2.9] QID: B3648 (P3647)

A reactor is initially operating at steady-state 60% power near the end of core life when a fully withdrawn control rod suddenly inserts completely into the core. No operator action is taken and the plant control systems stabilize the reactor at a power level in the power range.

Compared to the initial shutdown margin (SDM), the new steady-state SDM is ______; compared to the initial 60% power core $K_{\rm eff}$, the new steady-state core $K_{\rm eff}$ is ______.

- A. the same; smaller
- B. the same; the same
- C. less negative; smaller
- D. less negative; the same

KNOWLEDGE: K1.14 [2.6/2.9] QID: B3748 (P3747)

A nuclear plant has just completed a refueling outage. Reactor engineers have predicted a control rod configuration at which the reactor will become critical during the initial reactor startup following the refueling outage based on the expected core loading. However, the burnable poisons scheduled to be loaded were inadvertently omitted.

Which one of the following describes the effect of the burnable poison omission on achieving reactor criticality during the initial reactor startup following the refueling outage?

- A. The reactor will become critical before the predicted critical control rod configuration is achieved.
- B. The reactor will become critical after the predicted critical control rod configuration is achieved.
- C. The reactor will be unable to achieve criticality because the fuel assemblies contain insufficient positive reactivity to make the reactor critical.
- D. The reactor will be unable to achieve criticality because the control rods contain insufficient positive reactivity to make the reactor critical.

ANSWER: A.